

Fire Check-UK

Supply & Maintenance Of All Fire Safety Equipment

● FIRE ALARMS ● FIRE EXTINGUISHERS ● EMERGENCY LIGHTING ● SAFETY SIGNS ● RISK ASSESSMENTS ●

● FIRE TRAINING ● PAT TESTING ● FIRE ACCESSORIES ●

Certificate of Conformity

This is to certify that FireCheck-UK, a company registered with UKFA for the contract maintenance of portable extinguishers, fire alarms and emergency lights and a holder of a BSI QAS 3169.4/9 certificate, has inspected the portable fire extinguishers at your premises to ensure they are installed according to BS 5306: Part 8 and have been serviced as required by BS 5306: (Part 3) 2009 ■

The fire detection equipment is operational and has been tested in accordance with BS5389-1:2002 + A2:2008

The emergency lighting equipment is operational and has been tested in accordance with BS5266: Part 1: 2005 ■

Customer Details: AIR CONDITIONING SERVICES LTD

Location: COBNAR WOOD CLOSE CHESTERFIELD S41-9RQ

Date of Issue: NOVEMBER 2022

Date of Expiry: NOVEMBER 2023

Service Technician: RICHARD BAKER

:Inspections of all extinguishers, spare gas cartridges and replacement appliances should be carried out in accordance with BS5306-8: 2009 by the user or the user's representative at MONTHLY intervals to ensure that the appliances are in their proper position and have not been discharged, or lost pressure (in the case of extinguishers fitted with a pressure indicator) or suffered obvious damage.